



CALA

Canadian Association for
Laboratory Accreditation Inc.

CALA Directory of Laboratories

Membership Number: 3933

Laboratory Name: HV Oil Incorporated

Parent Institution:

Address: 5416 - 36 Street NW Edmonton AB T6B 3P3

Contact: Mr. Sudhir Kumar

Phone: (780) 485-9400

Fax: (780) 485-9444

Email: sudhirkumar@hvoil.com

Standard: Conforms with requirements of ISO/IEC 17025

Clients Served: All Interested Parties

Revised On: March 7, 2018

Valid To: January 23, 2019

Scope of Accreditation

Insulating Oil (Inorganic)

Dissolved Gases - Insulating Oil (010)

LBP12; ASTM D3612-C-02(09)

GC/FID

Acetylene

Carbon dioxide

Carbon monoxide

Ethane

Ethylene

Hydrogen

Methane

Nitrogen

Oxygen

Insulating Oil (Inorganic)

Water - Insulating Oil (004)

LBP04; ASTM D1533-12

Coulometric Karl Fischer Titration

Water

† "OSDWA" indicates the appendix is used for the analysis of Ontario drinking water samples, which is subject to the rules and related regulations under the Ontario "Safe Drinking Water Act" (2002).

The list of tests and measurement capabilities for which a laboratory is accredited can change at any time due to circumstances such as scope extensions, voluntary withdrawal of tests by the laboratory and suspension. Scopes are published by the CALA via the Internet at http://www.cala.ca/cala_directories.html